





## TEXTURE DETAILS SCALE 1:15

## NOTES:

- 1. GROOVES ON TEXTURED AREA ARE TO BE PLACED PERPENDICULAR TO THE CROSSWALK LINES OR WHERE NO CROSSWALK EXISTS, PERPENDICULAR TO A LINE BETWEEN THE TWO PEDESTRIAN RAMPS.
- 2. CONTROL JOINT MUST INTERCEPT THE BOTTOM OF RECESSED GROOVES.
- 3. CONTROL JOINT MUST BE SLIGHTLY DEEPER THAN RECESSED GROOVES.
- 4. DROP BACK OF WALK AS PER DRAWING 102-0002-023.
- 5. RETROFIT MAX. 8%, NEW BUILD 5%, MIN. 3% SLOPE.
- 6. SIDEWALK WIDTH VARIES ACCORDING TO STREET CLASSIFICATION REQUIREMENTS.

	PLAN DESCRIPTION/REVISION	DATE	BY		APPROVALS	
1	ORIGINAL STANDARD DRAWING 1	1999-AUG-25	RO	Saskatoon	Sapieha. Digitally signed by	Jurkiewi Digitally signed by Jurkiewicz, Matt
2	UPDATED TO ALIGN WITH THE DESIGN & DEVELOPMENT STANDARDS 2	2020-FEB-13	PRZ		Matio Date: 2025.04.14	Date: 2025.05.01
2	MANUAL AND POLICY CO7-030 - STREET DESIGN 2	2020-FEB-13	PRZ		00.20.00 =00 00	
3	UPDATED TO ALIGN WITH SIDEWALK BEST PRACTICES REPORT 2	2020-0CT-08	DLH		SIGNATURE	SIGNATURE
4	REVISED NOTES 2	2024-NOV-28	SJK	PEDESTRIAN RAMP		
Г				PEDESTRIAN RAMP	NAME	NAME
Г				TEXTURE DETAILS	l	
				· - · · · · · · · · · · · · · · · · · ·	DATE SIGNED	DATE SIGNED
					SCALES: PLAN NO.	
L					VERT 102-	·0002-026r004