


GASKETED PVC TEE-

GENERAL NOTES

- 1. INTERNAL DROP STRUCTURE TO BE USED IN
- 2. DROP PIPE SHALL BE ONE SIZE SMALLER THAN THE SEWER MAIN SIZE WITH A MINIMUM DROP PIPE SIZE OF 150mm DIAMETER AND A MAXIMUM OF 375mm DIAMETER.
- 3. STRAPS SHALL NOT BE PLACED WITHIN 100mm OF ANY MAINTENANCE HOLE SECTION JOINT.
- 4. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS NOTED OTHERWISE.



-APPROVED CORED HOLE COMPRESSION-TYPE CONNECTOR