



SERVICE JUNCTION BOX  
SEE DWG. 102-0016-019  
FOR JUNCTION BOX DETAILS

ELECTRICAL SERVICE  
DISCONNECT

NOTE: ALL INSTALLATIONS MUST  
COMPLY WITH THE CANADIAN  
ELECTRICAL CODE AND TECHNICAL  
AUTHORITY OF SASKATCHEWAN  
REQUIREMENTS.

RIGID SERVICE CONDUIT

53mm (2") HDPE CONDUIT  
TO TRAFFIC CABINET SERVICE  
JUNCTION BOX

GROUND PLATE 600mm  
MIN DEPTH

#6 BARE CU CONDUCTOR

PLAN DESCRIPTION/REVISION	DATE	BY
1 SERVICE DISCONNECT DETAIL	2024-DEC-23	SCT

  
**City of Saskatoon**  
 SERVICE DISCONNECT DETAILS  
 OVERHEAD SERVICE ROUGH IN  
 SPECIFICATION 12600-11

APPROVALS	
Buchko, Michelle <small>Digitally signed by Buchko, Michelle Date: 2026.03.24 11:48:59 -06'00'</small> SIGNATURE	Petras, Julian <small>Digitally signed by Petras, Julian Date: 2026.03.31 11:41:15 -06'00'</small> SIGNATURE
NAME	NAME
DATE SIGNED	DATE SIGNED
SCALES: HOR. NTS VERT.	PLAN NO. 102-0016-052r001