

Water Treatment Plant Permit to Operate Laboratory Report

2025 - FOURTH QUARTER WATER QUALITY REPORT

Procedures used are based upon recognized Provincial, Federal or U.S. method compendia such as CCME, APHA, EPA. The results relate only to the items tested or sampled. Unless qualified otherwise, all samples were received in acceptable condition. Estimated uncertainties and additional information provided upon request.

Test methods and data are validated by the laboratory's Quality Assurance Program. Analyses are conducted by ISO/IEC 17025 accredited laboratories for parameters listed on their respective scope. Parameters reported herein were analyzed by Sub-Contracted laboratories, except where indicated as analyzed by the City of Saskatoon Water Lab (*COS-WL parameter*).

Interpretation and use of test results are the sole responsibility of the Client/Customer. The retained laboratory is not responsible for the accuracy or any data impacts that result from the information provided by the Client/Customer or their agent.

Results authorized by:

Cleo Jahraus
Laboratory Services Coordinator - Water Treatment
831 11th Street West, Saskatoon, SK S7M 5Z4

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

PHYSICAL CHARACTERISTICS		Drinking Water LIMIT*	Drinking Water	Main Raw Water Intake
Colour, True	CU	15	<5.0	<5.0
Conductivity	µS/cm	none applied	494	496
pH	pH	7.0 to 10.5	8.27	8.27
Solids, Total Dissolved (TDS), calculated	mg/L	500	279	296
Solids, Total Suspended (TSS)	mg/L	none applied	<3.0	4.7
Turbidity	NTU	3	<0.10	2.74

CHEMICAL - General (Major Ions)		Drinking Water LIMIT*	Drinking Water	Main Raw Water Intake
Alkalinity, Total (as CaCO ₃)	mg/L	500	121	159
Alkalinity, Bicarbonate (HCO ₃)	mg/L	none applied	148	194
Alkalinity, Carbonate (CO ₃)	mg/L	none applied	<1.2	<1.2
Chloride (Cl)	mg/L	250	17.9	14.9
Chlorine (Cl ₂), Total (<i>COS-WL parameter</i>)	mg/L	0.5 - 3.0	1.8	
Fluoride (F)	mg/L	1.5	0.67	0.14
Hardness (Total as CaCO ₃), dissolved	mg/L	800	167	204
Calcium (Ca) - Dissolved	mg/L	none applied	35	49
Magnesium (Mg) - Dissolved	mg/L	200	19	20
Potassium (K) - Dissolved	mg/L	none applied	3.36	3.43
Sodium (Na) - Dissolved	mg/L	200	28	29
Sulfate (SO ₄)	mg/L	500	99	79

CHEMICAL - Health and Toxicity		Drinking Water LIMIT*	Drinking Water	Main Raw Water Intake
Aluminum (Al) - Total	mg/L	0.1	0.0173	0.0828
Antimony (Sb) - Total	mg/L	0.006	0.00013	0.00015
Arsenic (As) - Total	mg/L	0.01	0.00033	0.00121
Barium (Ba) - Total	mg/L	1	0.0511	0.0906
Boron (B) - Total	mg/L	5	0.034	0.029
Cadmium (Cd) - Total	mg/L	0.005	<0.0000050	0.0000134
Chromium (Cr) - Total	mg/L	0.05	<0.00050	<0.00050
Copper (Cu) - Total	mg/L	1	0.00118	0.00086
Cyanide (CN) - Total	mg/L	0.2	<0.0050	<0.0050
Iron (Fe) - Total	mg/L	0.3	<0.010	0.111
Lead (Pb) - Total	mg/L	0.005	<0.000050	0.000108
Manganese (Mn) - Total	mg/L	0.05	0.00014	0.0179
Mercury (Hg) - Total	mg/L	0.001	<0.0000050	<0.0000050
Selenium (Se) - Total	mg/L	0.01	0.000330	0.000379
Silver (Ag) - Total	mg/L	none applied	<0.000010	<0.000010
Uranium (U) - Total	mg/L	0.02	0.00109	0.00123
Zinc (Zn) - Total	mg/L	5	<0.0030	0.0034

OTHER		Drinking Water LIMIT*	Drinking Water	Main Raw Water Intake
Ammonia, Total (as N)	mg/L	none applied	0.460	0.0163
Nitrate (as N)	mg/L	10	0.040	0.049
Nitrate + Nitrite (as N)	mg/L	none applied	<0.0500	<0.050
Nitrite (as N)	mg/L	1	<0.010	<0.020
Total Kjeldahl Nitrogen (N)	mg/L	none applied	0.490	0.259
Nitrogen, Total	mg/L	none applied	0.530	0.308
Biochemical Oxygen Demand (5-day)	mg/L	none applied		<2.0
Carbon (TOC) - Total Organic	mg/L	none applied	2.28	3.48
Phenols	mg/L	none applied	<0.0010	<0.0010
Phosphate, Ortho-, Dissolved (as P)	mg/L	none applied	<0.050	<0.050
Phosphorus, Total	mg/L	none applied	<0.0020	0.0119

MICROORGANISMS		Drinking Water LIMIT*	Drinking Water	Main Raw Water Intake
Chlorophyll a (Plant Pigment)	µg/L	none applied		4.88
<i>E.coli</i> ** (COS-WL parameter)	MPN/100mL	0		105
Total Coliform (COS-WL parameter)	CFU/100mL	0	0	727
Background Non-Coliform (COS-WL parameter)	CFU/100mL	200	0	4850
<i>Giardia</i>	cysts/100 L	3 log inactivation		1.2
<i>Cryptosporidium</i>	oocysts/100 L	3 log inactivation		0.0
Microcystins***	µg/L	1.5		

TRIHALOMETHANES		Drinking Water LIMIT*	Drinking Water	East Distribution	West Distribution
• Bromodichloromethane	µg/L	none applied	6.0	5.7	5.0
• Bromoform	µg/L	none applied	<1.0	<1.0	<1.0
• Chloroform	µg/L	none applied	16.3	16.7	15.1
• Dibromochloromethane	µg/L	none applied	1.3	1.4	1.2
Total Trihalomethanes (calc)	µg/L	100	23.6	23.8	21.3

HALOACETIC ACIDS		Drinking Water LIMIT*	Drinking Water	East Distribution	West Distribution
• Bromochloroacetic Acid	µg/L	none applied	1.80	2.12	2.18
• Dibromoacetic Acid	µg/L	none applied	<1.00	<1.00	<1.00
• Dichloroacetic Acid	µg/L	none applied	6.76	6.99	6.33
• Monobromoacetic Acid	µg/L	none applied	<1.00	<1.00	<1.00
• Monochloroacetic Acid	µg/L	none applied	<1.00	<1.00	<1.00
• Trichloroacetic Acid	µg/L	none applied	4.82	5.77	5.37
Halo Acetic Acids 5, Total (calc)	µg/L	80	11.60	12.80	11.70

*Drinking Water Limit: This is the Limit for the parameter specified, as determined by Health Canada and/or the City of Saskatoon *Permit to Operate a Waterworks* issued by the Water Security Agency under the jurisdiction of the Saskatchewan Minister of Environment. Limits may be a MAC (Maximum Acceptable Concentration), Interim or Guideline MAC (MAC has yet to be determined) or AO (Aesthetic Objective - may affect acceptance of water by consumers but are not a health-based limit. Compliance within this range is not mandatory). Further information can be obtained by consulting the Health Canada document *Guidelines for Canadian Drinking Water Quality*.

**Analyzed only if indicated by a Total Coliform sample ≥ 1 cfu/100mL.

***Analyzed May to October only

Symbol of "<" means "less than" and indicates that the analyte was not detected above the stated level.

- END REPORT -