

## NOTE:

- 1. ALL FITTINGS WITHIN THE SERVICE BOXES TO BE BRASS.
- 2. SERVICE BOX TO BE SUPPLIED BY OWNER
- 3. INSTALL AS PER CLEARANCES SUGGESTED BY THE MANUFACTURER.
- 4. THREADED PVC PLUGS TO BE INSTALLED IN ALL OPEN END VALVES (ie. DRAINS & TEST COCKS ETC.).
- 5. ALL BOLTS TO BE STAINLESS STEEL.

701-9306-006r001



Drawing Title

Service Box for Parks:50mm

Scale

n.t.s.

Drawn: BT Checked: BT Date Y/M/D 2004/03/03

Drawing No.

2810 - 14

2005 Standard Detail