

October 19, 2023

City of Saskatoon
222 – 3rd Avenue North
Saskatoon, SK
S7K 0J5

ATTENTION: Adam Guider


Bulk Sample Analysis Report – Saskatoon Water Treatment Plant

Please see the laboratory results below for the bulk samples collected on October 5, 2023, from the Saskatoon Water Treatment Plant. The samples were analyzed for the identification of asbestos. Asbestos **was not** detected within any of the samples.

The results were obtained with the Asbestos Analysis of Bulk Materials via AHERA Method 40CFR 763 Subpart E Appendix E supplemented with EPA 600/R-93/116 using polarized light microscopy. The detection limit of this method is listed as less than 1% by volume.

This test report relates only to the materials sent for examination and any use or extension of the information by the client of these results is the responsibility of the client. If any questions arise, please contact our office at (306) 978-6665. Thank you for this opportunity of service.

Sincerely,



Bray Berschiminsky
Bersch Consulting Ltd.
B67BLJ05M – Saskatoon Water Treatment Plant



Brad Berschiminsky
Bersch Consulting Ltd.

Bulk Sample Analysis Report

October 19, 2023

Project Number: B67.23

Client: City of Saskatoon

Location: Saskatoon Water Treatment Plant - 831 11th Street West, Saskatoon, SK

File Number: B67BLJ05M

Sample #	Sample Date	Sample Material	Sample Location and Information	Asbestos	%	Analyst
1	2023/10/05	Lineal Pipe Insulation	1957 Filter Plant Basement On Pipeline with Newly Installed Valve	No Asbestos Detected		EMSL/WB
2	2023/10/05	Lineal Pipe Insulation	1957 Filter Plant Basement On Elbow Adjacent to Pipeline with Newly Installed Valve	No Asbestos Detected		EMSL/WB

Note: The results were obtained with the Asbestos Analysis of Bulk Materials via AHERA Method 40CFR 763 Subpart E Appendix E supplemented with EPA 600/R-93/116 using polarized light microscopy. The detection limit of this method is listed as less than 1% by volume.