

BERSCH & ASSOCIATES LTD.

July 12, 2013

City of Saskatoon
Infrastructure Services Department
1101 Avenue P North
Saskatoon, Sk.
S7L 7K6

ATTENTION: Brent Anderson

SUBJECT: Diefenbaker Park Workshop- Asbestos Registry Report

Please find attached our laboratory's results for the bulk material samples taken from Diefenbaker Park Workshop located at 2610 St. Henry Avenue, Saskatoon, SK. The samples were analyzed in our laboratory for the identification of asbestos.

The results for the samples submitted were obtained by examination in accordance with the current USEPA 600/R-93/116 Method for the analysis of asbestos in building materials using polarized light microscopy and dispersion staining techniques. The detection limit of this method is listed as less than 1% by volume.

This test report relates only to the materials sent for examination and any use or extension of the information by the client of these results is the responsibility of the client. If any questions arise on the results of the attached information please contact our office. Thank you for this opportunity of service!

The floor plans identifying the sample locations and photos of the bulk material samples are attached to this report.

Sincerely,

Dustin Fraess
Bersch & Associates Ltd.
File: B67BLE23

Bersch & Associates Ltd.

B67BAE23

Box 3568
Humboldt, Sask. S0K 2A0

BULK SAMPLE ANALYSIS REPORT


PROJECT NO. B67.13

CLIENT: City of Saskatoon
Infrastructure Services - Facilities Branch

Contact: Brent Anderson

Location: Diefenbaker Park Workshop - 2610 St. Henry Avenue, Saskatoon, SK.

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST
B1	23-May-13	Washroom - 1' x 1' floor tile, beige with brown streak	None detected		WB



#__ - Sample # Location

NOTE:
THESE DRAWINGS HAVE BEEN PREPARED
BASED ON INFORMATION PROVIDED BY
OTHERS. THE CITY HAS TAKEN STEPS
TO VERIFY THE ACCURACY AND/OR
COMPLETENESS OF THIS INFORMATION
BUT SHALL NOT BE RESPONSIBLE FOR
AND ERRORS OR OMISSIONS THAT
MAY BE INCORPORATED AS A RESULT
OF ERRONEOUS INFORMATION PROVIDED
BY OTHERS THAT WAS NOT ABLE TO BE
VISUALLY CONFIRMED.

- GENERAL NOTES:**
1. ALL DIMENSIONS ARE IN MILLIMETRES
 2. DRAWINGS ARE NOT TO BE SCALED.
 3. ALL DRAWINGS TO BE READ IN CON-
JUNCTION WITH THE SPECIFICATIONS
UNLESS OTHERWISE NOTED.
 4. VERIFY SITE CONDITIONS, DIMENSIONS
AND LOCATION OF ALL UTILITIES PRIOR
TO THE START OF CONSTRUCTION.
 5. REPORT ALL DISCREPANCIES TO THE
CONSULTANT.

REV. ISSUED FOR DATE

DESIGNED BY: DRAWN BY: CHECKED BY: APPROVED BY:
TO

SCALE: N.T.S. DATE: 04/05/09

SHEET NAME
Main Floor
Floor Plan

PROJECT TITLE
774
Diefenbaker Pk
Washrooms

PROJECT NO. SHEET
Page 123

BULK SAMPLE PHOTOS

#1) Floor Tile

