




150mm VERTICAL CURB

NOTES:

1. CONCRETE STANDARD:
32 MPa DURA-MIX CONCRETE
5-8% AIR AS PER SPEC.
2. COMPACTION STANDARD:
98% STANDARD PROCTOR AS PER SPEC.
3. BROOM FINISH WALK, CURB FACE & GUTTER.
BROOM OVER ALL CONTROL JOINTS.
4. SPACING OF CONTROL JOINTS TO BE 1.5m.
5. VERIFY SIDEWALK WIDTH ACCORDING TO STREET CLASSIFICATION REQUIREMENTS. SIDEWALK WIDTH MAY VARY TO MATCH EXISTING FOR RETROFIT APPLICATIONS.

PLAN DESCRIPTION/REVISION			DATE	BY	APPROVALS			
1	ORIGINAL STANDARD DRAWING		1999-FEB-01	RO			 SIGNATURE Christopher Duriez	
2	UPDATED TO ALIGN WITH THE DESIGN & DEVELOPMENT STANDARDS		2020-FEB-13	PRZ			 SIGNATURE Maciej Jurkiewicz	
2	MANUAL AND POLICY C07-030 - STREET DESIGN		2020-FEB-13	PRZ			NAME Christopher Duriez	
3	UPDATED TO ALIGN WITH SIDEWALK BEST PRACTICES REPORT		2020-SEP-15	DLH			NAME Jan 25, 2021	
					COMBINED SIDEWALK & VERTICAL CURB		DATE SIGNED Jan 25, 2021	
							DATE SIGNED Jan 25, 2021	
							SCALES: HOR. 1:15 VERT.	
							PLAN NO. 102-0002-033r003	