




NOTES:

1. CONCRETE STANDARD:  
32 MPa DURA-MIX CONCRETE  
5-8% AIR AS PER SPEC.
2. COMPACTION STANDARD:  
98% STANDARD PROCTOR AS PER SPEC.
3. BROOM FINISH WALK, CURB FACE & GUTTER.  
BROOM OVER ALL CONTROL JOINTS.
4. SPACING OF CONTROL JOINTS TO BE 1.5m.
5. VERIFY SIDEWALK WIDTH ACCORDING TO STREET CLASSIFICATION REQUIREMENTS.  
SIDEWALK WIDTH MAY VARY TO MATCH EXISTING FOR RETROFIT APPLICATIONS.

PLAN DESCRIPTION/REVISION			DATE	BY	 <p>COMBINED SIDEWALK, REVERSED VERTICAL CURB &amp; GUTTER</p>	APPROVALS	
1	ORIGINAL STANDARD DRAWING		2000-JUL-10	RK		 SIGNATURE Christopher Duriez	 SIGNATURE Maciej Jurkiewicz
2	UPDATED TO ALIGN WITH THE DESIGN & DEVELOPMENT STANDARDS		2020-FEB-13	PRZ		NAME Jan 25, 2021	NAME Jan 25, 2021
2	MANUAL AND POLICY C07-030 - STREET DESIGN		2020-FEB-13	PRZ		DATE SIGNED	DATE SIGNED
3	UPDATED TO ALIGN WITH SIDEWALK BEST PRACTICES REPORT		2020-SEP-15	DLH	SCALES: HOR. 1:15 VERT.	PLAN NO. 102-0002-036r003	