



City of  
**Saskatoon**

**Transportation & Construction Department**

Construction & Design

To: Mueller Canada  
All Developers  
Water and Sewer Contractors  
Waterworks Distributors  
Utilities & Environment  
Community Services Department  
Saskatoon Fire  
Supply Chain Management Division  
Transportation & Construction

Date: February 21, 2019

File No.: 7820-1

From: Matt Jurkiewicz  
Acting Director, Construction & Design

**Re: Discontinue Purchase and Installation of Mueller Canada Modern and Super Centurion Hydrants**

---

The City of Saskatoon ("City") has encountered a contaminated condition in hydrants. The City is currently investigating the situation.

As a result, effective immediately, the City is removing the hydrants below from the approved products list:


- Mueller Canada - Modern Centurion with oil filled reservoir
- Mueller Canada - Super Centurion with oil filled reservoir

These hydrants will be disallowed until further notice.

This suspension *does not include* the purchase and installation of replacement parts for maintenance purposes, or the requirement of replacing hydrants fully installed prior to the date of this Memorandum.

If you have any concerns or questions contact 306-657-8778.

Approved by:

  
\_\_\_\_\_  
Trevor Bell, Acting General Manager  
Utilities & Environment Department  
Dated: Feb 20, 2019

Cc: Solicitors, City Solicitor's Office  
Director, Supply Chain Management  
General Manager, Transportation & Construction

---

**Memorandum**