

Revisions to Standard Construction Specifications & Drawings Effective February 3, 2023

City of Saskatoon Notification:

The following standard construction specifications and drawings have been added, revised or withdrawn as described.

To access the current specifications and drawings, please visit the City of Saskatoon specifications and standards website:

https://www.saskatoon.ca/business-development/development-regulation/specifications-standards

SPECIFICATION CHANGES

Bold Text within a specification on the website indicates a change.

Division 02 - Earthworks

02005 Excavation and Embankment Construction

 Clarified limits for acceptable moisture within 2% of optimum moisture content in subsection 5 Testing.

Division 08 - Water and Sewer

08000 - Construction Materials - General

 Added Product Petro Coating Systems – Petrolatum Tape to subsection 4.2 Field Coatings.

08010 - Construction Materials - Water Mains

- Added maximum allowable trench length of 100 meters to subsection 3.2 Trenching.
- Clarified limits for acceptable moisture within 2% of optimum moisture content in subsection 9.2.2 Class 2 Backfill.
- Added new subsection detailing remediation requirements in subsection 9.2.5 Trench, pipe and backfill remediation after rain events

08020 - Catch Basin Construction

• Added information to clarify the conditions under which catch basin barrels might be left lower than 225mm, and 50mm rubber adjustment rings may be used.

08025 - Water and Sewer Connections Construction

Added maximum allowable trench length of 100 meters in subsection 5.3
Trenching



- Clarified limits for acceptable moisture within 2% of optimum moisture content in subsection 11 Backfill
- Changed "augured" to "tunneled" to include the different methods that may result in the formation of tunnels, including, but not limited to auguring in subsection 11.3 Backfilling Tunnels.
- Changed Activity 9 Refundable Deposit for Boulevard Condition Maintenance as Part of Demolition Permit to \$150.00/meter frontage Residential, \$200.00/meter frontage Commercial in Table 2 Inspection Fees, Tapping Fees, and refundable Deposits.

08030 - Water Main Construction

- Added maximum allowable trench length of 100 meters to subsection 3.2 Trenching.
- Clarified limits for acceptable moisture within 2% of optimum moisture content to subsection 12.2.2 Class 2 Backfill.

Division 15 - Construction Materials

15002 - Construction Materials - Water Service Connections

 Added Product Mueller 300 ball Curb Valve (B-25209N) to subsection 3.2 Curb Stops

15005 - Construction Materials - Corrosion Protection

 Added product Petro Coating Systems – Petrolatum Tape to subsection 1.2 Corrosion Prevention tape.



DRAWINGS CHANGES

Drawings marked "WITHDRAWN" in previous version have been removed.

Revised Drawings

- Revised to add note "Travel and Parking Lane Widths Independent of Gutter Width"
 - 102-0002-062r004 Traffic Calming Curb Extensions at T-Intersection (Collector & Local Streets)
 - 102-0002-064r004 Traffic Calming Curb Extensions at a Mid-Block Crossing (Collector Street)
 - 102-0002-065r004 Traffic Calming Curb Extension Options (Collector or Local Streets)
- Revised to align with Design and development Standards Manual and Policy C07-030 – Street Design
 - o 102-0012-016r002 Fire Hydrant Standard Locations

END OF LOG OF CHANGES

If you have any questions or concerns, please contact customer service by phone at 306-975-2476 or by email at CustomerCare@saskatoon.ca to be directed to the appropriate party.